



# 2020 Water Quality Report

COVINA KNOLLS SYSTEM

This report reflects water quality testing conducted during 2020.



## *A Word of Assurance about*



## Your 2020 Water Quality Report

Your drinking water is constantly monitored from source to tap for regulated and unregulated constituents through comprehensive drinking water quality compliance testing programs carried out by dedicated Suburban Water Systems (Suburban) professionals.

Certified quality assurance professionals collect hundreds of water samples each year to safeguard the quality of your tap water. These samples are analyzed in the field at the time of sample collection or by independent, state-certified laboratories for various substances as mandated by law. The results of these samples are then submitted to the California State Water Board (SWB), which oversees water quality compliance for all public water systems in California. Covina Irrigating Company (CIC), the source of our water in 2020, has its own comprehensive drinking water source and treatment monitoring programs that comply with the United States Environmental Protection Agency (USEPA) and SWB California regulatory requirements.





*For more than 60 years, Suburban has provided dependable, high-quality water that complies with all federal and state health safety standards to thousands of families in the San Gabriel Valley and nearby areas. We are proud to report that 2020 was no exception.*

## Who We Serve

Suburban provides drinking water to the area of Covina called Covina Knolls. Suburban serves approximately 2,000 people. In 2020, Suburban purchased all of its Covina Knolls drinking water from CIC. CIC filters and disinfects local surface water from the San Gabriel Mountains and imported water from the California State Water Project. If needed, Suburban can purchase treated water from the Walnut Valley Water District.

## Suburban's Drinking Water Complies with All Health and Safety Regulations

In order to ensure that tap water is safe to drink, the USEPA and the SWB prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. SWB regulations also establish limits for contaminants in bottled water, which must provide the same protection for public health.

Last year, as in the past, Suburban's drinking water was in full compliance with all applicable county, state and federal drinking water regulations. Our system of pumps, reservoirs and distribution pipelines are all routinely inspected, monitored and maintained by professional state-certified water system operators to protect the quality of the water from source to tap.



# Purpose of this Report





This annual water quality report demonstrates Suburban's compliance with SWB and USEPA regulations. It also provides important information to the public about where drinking water comes from, how drinking water is regulated, and what types of contaminants may be in the drinking water. You will find charts on the following page, which summarize the results of a comprehensive water quality testing program.

You can determine how the water quality in your area compares to government standards by finding the average values in the charts and comparing these values to the maximum contaminant level (MCL).

Chemicals reported in the table were detected in the water by independent accredited laboratories during 2020 or from the most recent tests. Most, but not all, of these chemicals are minerals, metals, and radiologicals occurring naturally in the water. Some of these chemicals, however, are the result of 1) drinking water treatment processes — chlorine residual, disinfection byproducts, aluminum; 2) agricultural practices that occurred many decades ago — nitrate; and 3) household plumbing — copper.

To help you understand what these test results mean, we have also included information about significant constituents, measurements, water quality definitions and advisories.



## Are There Risks?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.



## Household Issues that May Affect You or Your Water Quality...

**Hot Water Heaters:** Many odor complaints may be traced to the home's hot water heater. Remember to follow manufacturer's instructions and flush hot water heaters regularly. This will flush out any sediments that may have accumulated, provide good water turnover to maximize water quality, and help keep your unit in good working order.

**Point of Use or Home Water Filtration Units:** Be vigilant in changing or cleaning any filters or media on your home units. Always follow the manufacturers instructions. Remember, the water is only as clean as the filter allows. Improperly maintained filters can deliver very poor quality water.



## Contaminants that May Be in the Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the

ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

### *Contaminants that may be present in source water include:*



**Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.



**Inorganic contaminants**, such as salts and metals that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.



**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.



**Organic chemical contaminants**, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application and septic systems.



**Radioactive contaminants** that can be naturally-occurring or be the result of oil and gas production and mining activities.



**Lead**, if present in elevated levels, can cause serious health problems, especially for pregnant women and young children.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Suburban is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800) 426-4791 or at [www.epa.gov/lead](http://www.epa.gov/lead).



# SUBURBAN WATER SYSTEMS-COVINA KNOLLS DRINKING WATER SOURCES TESTED IN 2020

## Covina Irrigating Company Filtered San Gabriel River and State Water Project Water

Chemical	Met Standard?	Year Tested	Units	Average	Range	MCL	PHG (MCLG)	Typical Source of Contaminant
<b>Primary Standards</b>								
Aluminum (ppm)	Yes	2020	ppm	0.08	ND - 0.2	1	0.6	Treatment Chemical Residue
Arsenic	Yes	2020	ppb	3	ND - 4	10	0.004	Runoff or Leaching from Natural Deposits
Fluoride	Yes	2020	ppm	0.2	ND - 0.3	2	1	Runoff or Leaching from Natural Deposits
Gross Alpha Radiation	Yes	2015	pCi/L	3	3	15	(0)	Erosion of Natural Deposits
Nitrate	Yes	2020	ppm-N	<0.4	ND - 1	10	10	Fertilizers, Septic Tanks
Uranium	Yes	2015	pCi/L	2	2	20	0.43	Erosion of Natural Deposits
<b>Secondary Standards*</b>								
Aluminum (ppb)	Yes	2020	ppb	81	ND - 200	200*	600	Treatment Chemical Residue
Chloride	Yes	2020	ppm	55	50 - 60	500*	n/a	Runoff or Leaching from Natural Deposits
Odor	Yes	2020	TON	ND	ND	3*	n/a	Naturally-Occurring Organics
Specific Conductance	Yes	2020	µmho/cm	390	380 - 400	1,600*	n/a	Ions in Water; Seawater Influence
Sulfate	Yes	2020	ppm	32	25 - 38	500*	n/a	Runoff or Leaching from Natural Deposits
Total Dissolved Solids	Yes	2020	ppm	220	220	1,000*	n/a	Runoff or Leaching from Natural Deposits
<b>Unregulated</b>								
Alkalinity, total	n/a	2020	ppm CaCO3	135	100 - 170	n/r	n/a	Runoff or Leaching from Natural Deposits
Calcium	n/a	2020	ppm	17	8 - 26	n/r	n/a	Runoff or Leaching from Natural Deposits
Hardness, total	n/a	2020	ppm CaCO3	135	110 - 160	n/r	n/a	Runoff or Leaching from Natural Deposits
Hardness, total	n/a	2020	grains/gallon	9	6 - 9	n/r	n/a	Runoff or Leaching from Natural Deposits
Magnesium	n/a	2020	ppm	11	10 - 12	n/r	n/a	Runoff or Leaching from Natural Deposits
pH	n/a	2020	pH units	7.9	7.7 - 8.0	n/r	n/a	Acidity, Hydrogen Ions
Potassium	n/a	2020	ppm	3	3	n/r	n/a	Runoff or Leaching from Natural Deposits
Sodium	n/a	2020	ppm	28	13 - 42	n/r	n/a	Runoff or Leaching from Natural Deposits
Total Organic Carbon (ppm)	Yes	2020	ppm	2	2 - 3	Treatment Technique		Various Natural Decaying Sources

**ppb** = parts-per-billion; **ppm** = parts-per-million; **ppt** = parts-per-trillion; **pCi/L** = picoCuries per liter; **ntu** = nephelometric turbidity units; **ND** = not detected; **n/a** = not applicable;

**µmho/cm** = micromho per centimeter; **< =** average is less than the detection limit for reporting purposes; **MCL** = Maximum Contaminant Level; **(MCLG)** = federal MCL Goal;

**PHG** = California Public Health Goal; **NL** = Notification Level; **n/r** = not regulated. **\*Contaminant is regulated by a secondary standard to maintain aesthetic quality.**

Turbidity - Combined Filter Effluent	TT	Value	Met Standard?	Source	Turbidity is a measure of the cloudiness of the water, an indication of particulate matter, some of which might include harmful microorganisms. Low turbidity CIC's treated water is a good indicator of effective filtration. Filtration is called a treatment technique (TT). A treatment technique is a required process intended to reduce the level of contaminants in drinking water that are difficult and sometimes impossible to measure directly.
<b>Covina Irrigating Company Temple Filtration Plant</b>					
1) Highest single turbidity measurement	0.3	0.29	Yes	Run-Off	
2) Percentage of samples less than 0.3 NTU	95%	100	Yes	Run-Off	

# SUBURBAN WATER SYSTEMS COVINA KNOLLS DISTRIBUTION SYSTEM WATER QUALITY TESTED IN 2020

Chemical (Units)	Met Standard?	MCL (MRDL/MRDLG)	Average	Range	Typical Source of Contaminant
<b>Disinfection Byproducts</b>					
Total Trihalomethanes (ppb)	Yes	80	29	17 - 37	Byproducts of Chlorine Disinfection
Haloacetic Acids (ppb)	Yes	60	14	3 - 16	Byproducts of Chlorine Disinfection
Chlorine Residual (ppm)	Yes	(4 / 4)	2.5	1 - 3	Disinfectant Added for Treatment
<b>Aesthetic Quality</b>					
Color (Color Units)	Yes	15*	<3	ND - 7.5	Erosion of Natural Deposits
Turbidity (ntu)	Yes	5*	0.4	ND - 3	Erosion of Natural Deposits
Odor (threshold odor number)	Yes	3*	1	1 - 2	Erosion of Natural Deposits
Two locations in the distribution system are tested quarterly for total trihalomethanes and haloacetic acids; one location is tested weekly for color, odor and turbidity. <b>MRDL</b> = Maximum Residual Disinfectant Level; <b>MRDLG</b> = Maximum Residual Disinfectant Level Goal; <b>ntu</b> = nephelometric turbidity units; <b>ND</b> = not detected; <b>&lt;</b> = average is less than the detection limit for reporting purposes;					
*Contaminant is regulated by a secondary standard to maintain aesthetic qualities.					
<b>Bacterial Quality</b>	<b>Met Standard?</b>	<b>MCL</b>	<b>MCLG</b>	<b>Number Positive</b>	<b>Typical Source of Contaminant</b>
Total Coliform Bacteria	Yes	No more than 1 positive total coliform in a month	0	0	Bacteria that occur naturally in soils and water
<b>Lead and Copper</b>	<b>Met Standard?</b>	<b>Action Level</b>	<b>PHG</b>	<b>90th Percentile</b>	<b>Typical Source of Contaminant</b>
Copper (ppm)	Yes	1.3	0.3	0.3	Corrosion of Household Plumbing
Lead (ppb)	Yes	15	0.2	ND	Corrosion of Household Plumbing
The most recent lead and copper at-the-tap samples were collected from residences in 2019. None of the 10 samples for lead and copper exceeded the respective Action Level (AL). A regulatory Action Level is the concentration of a contaminant which if exceeded triggers treatment or other requirements that a water system must follow.					

## Water Quality Goals

The water Suburban delivers to your home meets standards required by USEPA, SWB and California Public Utilities Commission (PUC). Often, Suburban goes beyond what is required to monitor for constituents that have known health risks. The company uses only independent, state-certified water quality laboratories for testing. The charts in this report include two types of water quality goals:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.
- **Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

## Water Quality Standards

The quality of drinking water in the United States is regulated by the USEPA. Two state agencies, the SWB and the PUC, supplement and enforce federal USEPA standards. Standards established by these agencies are used to set limits for substances that may affect health or aesthetic qualities of water. The water quality charts in this report cover the following standards:

- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste and appearance of drinking water.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Primary Drinking Water Standard (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, as well as water treatment requirements.
- **Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.



# Source Water and Water Quality Assessments

In 2020, Suburban distributed treated surface water from CIC. CIC filters and disinfects local San Gabriel mountains water and California State Project water using an advanced disinfection technology process installed in 2015. CIC replaced sodium hypochlorite (bleach) with ultraviolet light (UV) as the primary disinfectant and chloramines in place of free chlorine as the residual disinfectant. The change in the



disinfection process reduces the level of certain regulated chemicals previously formed by the addition of bleach.

CIC completed source water assessments in accordance with the federal Safe Drinking Water Act. The purpose of the source water assessment is to promote source water protection by identifying types of activities in the proximity of sources which could pose a threat to the water quality. Every five years, CIC is required to examine and update possible sources of drinking water contamination in their surface water source waters. These reports are called watershed sanitary surveys.

CIC completed an update of its San Gabriel River watershed sanitary survey in 2015. The survey concluded that CIC's surface water is vulnerable to contamination from erosion, debris removal, forest fires and recreational activities. You may request summaries of the assessments by contacting Ken Reich, Suburban Quality Assurance Reporting Manager, at (626) 543-2575 or you may request complete copies from the SWB at (818) 551-2049.

## Water Quality Advisories

### Chloramines

CIC converts free chlorine to chloramines as its residual disinfectant. Chlorine and ammonia are combined at the CIC treatment facility to produce these chloramines. Chloramines are added to the water for public health protection because they prevent regrowth of bacteria in the distribution system pipes and also reduce the formation of certain chemicals that are regulated in drinking water. All of Suburban's water has some form of chlorine disinfectant residual at all times.

**Be advised that kidney dialysis units and aquarium owners must remove chloramines from water prior to use.** Hospitals or dialysis centers should be aware of the chloramines from water and should install proper chloramine removal equipment, such as carbon adsorption units. Aquarium owner owners can use readily available products to remove or neutralize chlorine. Chloraminated water is safe for people and animals to drink, and for all other general uses. Should you have any questions or concerns regarding chloramine in your water, please contact Ken Reich, Quality Assurance Reporting Manager at (626) 543-2575.



# The Quality of Your Water Is Our Primary Concern



This report contains important information about your drinking water. Translate it, or speak with someone who understands it.

يحتوي هذا التقرير على معلومات هامة عن نوعية ماء الشرب في منطقتك. يرجى ترجمته، أو ابحث التقرير مع صديق لك يفهم هذه المعلومات جيدا.

这份报告中有些重要的信息，讲到关于您所在社区的水的品质。请您找人翻译一下，或者请能看得懂这份报告的朋友给您解释一下。

इस रिपोर्ट में "पीने के पानी" के विषय पर बहुत जरूरी जानकारी दी गई है। कृपया इसका अनुवाद करें, या किसी जानकार से इस बारे में पूछें।

Arabic Chinese Hindi

この資料には、あなたの飲料水についての大切な情報が書かれています。内容をよく理解するために、日本語に翻訳して読むか説明を受けてください。

이 보고서는 귀하의 거주하는 지역의 수질에 관한 중요한 정보가 들어 있습니다. 이것을 번역하거나 충분히 이해하시는 친구와 상의하십시오.

Este reporte contiene información importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Japanese Korean Spanish

Ang ulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa iyong pag-inom ng tubig. Isalin ito, o makipag-usap sa isang tao na nauunawaan ito.

Bản báo cáo có ghi những chi tiết quan trọng về phẩm chất nước trong cộng đồng quý vị. Hãy nhờ người thông thạo, hoặc hỏi một người bạn biết rõ về vấn đề này.


Tagalog Vietnamese

## How to Read Your Water Meter

Your water meter is usually located between the sidewalk and curb under a cement cover. Remove the cover by inserting a screwdriver in the hole in the lid and then carefully lift the cover. The meter reads straight across, like the odometer on your car. Read only the black numbers (0895).

If you are trying to determine if you have a leak, turn off all the water in your home, both indoor and outdoor faucets, and then check the dial for any movement of the low-flow indicator. If there is movement, that indicates a leak between the meter and your plumbing system.

- Low-Flow Indicator** ~ The low flow indicator will spin if any water is flowing through the meter.
- Sweep Hand** ~ Each full revolution of the sweep hand indicates that one cubic foot of water (7.48 gallons) has passed through the meter. The markings at the outer edge of the dial indicate tenths and hundredths of one cubic foot.
- Meter Register** ~ The meter register is a lot like the odometer on your car. The numbers keep a running total of all the water that has passed through the meter. The register shown here indicates that 89,505 cubic feet of water has passed through this meter.



### Public Participation Opportunities

We value your input, concerns and suggestions. Please contact **Lauren James, Communications Manager**, at (626) 543-2531 or email her at [LJames@swwc.com](mailto:LJames@swwc.com) to inquire about possible future public participation opportunities. Also, please feel free to contact **Ken Reich, Quality Assurance Reporting Manager**, at (626) 543-2575, if you have any questions about water quality. In addition, a number of local water boards hold monthly meetings that are open to the public, including:

**Metropolitan Water District of Southern California**  
Second Tuesday of the month, (213) 217-6000

**Main San Gabriel Basin Watermaster**  
First Wednesday of the month, (626) 815-1300

**Three Valleys Municipal Water District**  
First and third Wednesday of the month, (909) 621-5568.



**Suburban Water Systems**

A SouthWest Water Company

**District Office: San Jose Hills**  
2235 E. Garvey Avenue North, Suite A  
West Covina, California 91791

Customer Service: (626) 543-2640  
[sanjosehills@swwc.com](mailto:sanjosehills@swwc.com)

[www.swwc.com/suburban](http://www.swwc.com/suburban)