



2021 Water Quality Report

LA MIRADA SYSTEM

This report reflects water quality testing conducted during 2021.



A Word of Assurance about

Your 2021 Water Quality Report

Your drinking water is constantly monitored from source to tap for regulated and unregulated constituents through comprehensive drinking water quality compliance testing programs carried out by dedicated Suburban Water Systems (Suburban) professionals.

Certified quality assurance professionals collect several thousand water samples each year to safeguard the quality of your tap water. These samples are analyzed in the field at the time of sample collection or by independent, state-certified laboratories for various substances as mandated by law. The results of these samples are then submitted to the California State Water Resources Control Board (SWRCB) - Department of Drinking Water (DDW), which oversees water quality compliance for all public water systems in California.





For more than 60 years, Suburban has provided dependable, high-quality water that complies with all federal and state health safety standards to thousands of families. We are proud to report that 2021 was no exception.



Who We Serve

Suburban's La Mirada system provides drinking water to the City of La Mirada, and portions of Whittier, Buena Park and Fullerton. Suburban serves approximately 55,000 people in its La Mirada system service area. In 2021 Suburban provided drinking water for its La Mirada service area from wells in the Main San Gabriel Groundwater Basin (MSGB) and the Central Groundwater Basin.



Suburban's Drinking Water Complies with All Health and Safety Regulations

To ensure that tap water is safe to drink, the USEPA and the SWRCB prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. SWRCB regulations also establish limits for contaminants in bottled water, which must provide the same protection for public health. Last year, as in the past, Suburban's drinking water was in full compliance with all applicable county, state and federal drinking water regulations. Our system of pumps, reservoirs and distribution pipelines are all routinely inspected, monitored and maintained by professional state-certified water system operators to protect the quality of the water from source to tap.



Purpose of this Report

This annual water quality report demonstrates Suburban's compliance with SWRCB and USEPA regulations. It also provides important information to the public about where drinking water comes from, how drinking water is regulated, and what types of contaminants may be in the drinking water. You will find charts on the following pages, which summarize the results of our comprehensive water quality testing program.

You can determine how the water quality in your area compares to government standards by finding the average values in the charts and comparing these values to the maximum contaminant level (MCL).

Chemicals reported in the table were detected in the water by independent accredited laboratories during 2021 or from the most recent tests. Most, but not all, of these chemicals are minerals, metals and radiologicals occurring naturally in the water. Some of these chemicals, however, are the result of 1) drinking water treatment processes – chlorine residual, disinfection byproducts) agricultural/industrial practices that occurred many decades ago – nitrate, tetrachloroethylene, perchlorate, trichloroethylene 3) household plumbing – copper; and 4) unknown sources responsible for detections of per-and-polyfluorinated alkyl substances (PFAS). To help you understand what these test results mean, we have also included information about significant constituents, measurements, water quality definitions and advisories.



Are There Risks?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.



Per- and Polyfluoroalkyl Substances (PFAS)

are a family of manmade chemicals prevalent in the environment and thousands of consumer products used daily, such as water-resistant clothing, carpet, food wrappers, non-stick cookware, cleaning products and more. PFAS have been detected in groundwater in various locations throughout the United States. Much remains unknown about PFAS, however, most research suggests that PFAS enter groundwater from various waste disposal activities.

Suburban voluntarily tested wells in our La Mirada/Whittier service area revealing the presence of these chemicals, particularly perfluorooctane sulfonic acid (PFOS) and perfluorooctanoic acid (PFOA). The origin of these contaminants is currently unknown. Suburban took immediate measures to minimize levels of PFAS.

Suburban is committed to delivering safe, high-quality water to the customers we serve.



Contaminants that May Be in the Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the

ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:



Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.



Inorganic contaminants, such as salts and metals that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.



Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.



Organic chemical contaminants, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application and septic systems.



Radioactive contaminants that can be naturally-occurring or be the result of oil and gas production and mining activities.



Lead, if present in elevated levels, can cause serious health problems, especially for pregnant women and young children.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Suburban is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800) 426-4791 or at www.epa.gov/lead.



SUBURBAN WATER SYSTEMS-LA MIRADA DRINKING WATER SOURCES TESTED IN 2021

				LOCAL GROUNDWATER				
Chemical	Met Standard?	Year Tested	Units	Average	Range	MCL	PHG (MCLG)	Typical Source of Contaminant
Primary Standards								
Arsenic	Yes	2021	ppb	3	ND - 14	10	0.004	Erosion of Natural Deposits
Barium	Yes	2021	ppm	ND<0.1	ND - 0.13	1	1	Erosion of Natural Deposits
Fluoride	Yes	2021	ppm	0.4	0.2 - 0.5	2	1	Erosion of Natural Deposits
Nitrate	Yes	2021	ppm-N	1	ND - 5	10	10	Fertilizers, Septic Tanks
Perchlorate	Yes	2021	ppb	ND<2	ND - 4	6	2	Industrial Contamination
Tetrachloroethylene (PCE)	Yes	2021	ppb	ND<0.5	ND - 1	5	0.06	Industrial Solvent Contamination
Trichloroethylene (TCE)	Yes	2021	ppb	ND<0.5	ND - 1	5	1.7	Industrial Solvent Contamination
Uranium	Yes	2021	pCi/L	2	ND - 4	20	0.43	Erosion of Natural Deposits
Secondary Standards*								
Chloride	Yes	2021	ppm	52	20 - 110	500*	n/a	Erosion of Natural Deposits
Color	Yes	2021	color unit	3	0 - 8	15*	n/a	Naturally-Occurring Substances
Manganese	Yes	2021	ppm	0.02	ND - 0.05	0.05*	n/a	Erosion of Natural Deposits
Odor	Yes	2021	TON	ND<1	ND - 1	3*	n/a	Naturally-Occurring Organic Matter
Specific Conductance	Yes	2021	µmho/cm	694	490 - 970	1,600*	n/a	Mineral Ions in Water
Sulfate	Yes	2021	ppm	81	41 - 150	500*	n/a	Erosion of Natural Deposits
Total Dissolved Solids	Yes	2021	ppm	363	280 - 580	1,000*	n/a	Erosion of Natural Deposits
Turbidity	Yes	2021	ntu	ND<0.1	ND - 0.1	5*	n/a	Erosion of Natural Deposits
Unregulated								
Alkalinity, total	n/a	2021	ppm CaCO3	194	150 - 220	n/r	n/a	Erosion of Natural Deposits
Calcium	n/a	2021	ppm	50	25 - 87	n/r	n/a	Erosion of Natural Deposits
Hardness, total	n/a	2021	ppm CaCO3	176	102 - 290	n/r	n/a	Erosion of Natural Deposits
Hardness, total	n/a	2021	grains/gallon	10	6 - 17	n/r	n/a	Erosion of Natural Deposits
Magnesium	n/a	2021	ppm	12	10 - 17	n/r	n/a	Erosion of Natural Deposits
Perfluorooctanoic acid (PFOA)	n/a	2021	ppt	8	7-9	n/r	RL = 10	Landfills, wastewater
Perfluorooctane sulfonic acid (PFOS)	n/a	2021	ppt	15	14-18	n/r	RL = 40	Landfills, wastewater
Perfluorobutanesulfonic acid (PFBS)	n/a	2021	ppt	4	4-5	n/r	RL = 5000	Landfills, wastewater
Perfluorohexanoic acid (PFHxA)	n/a	2021	ppt	4	3-5	n/r	n/a	Landfills, wastewater
Perfluorohexanesulfonate (PFHxS)	n/a	2021	ppt	3	3-4	n/r	n/a	Landfills, wastewater
pH	n/a	2021	pH units	7.8	7.6 - 7.9	n/r	n/a	Acidity, Hydrogen Ions
Potassium	n/a	2021	ppm	3	3 - 5	n/r	n/a	Erosion of Natural Deposits
Sodium	n/a	2021	ppm	78	17 - 120	n/r	n/a	Erosion of Natural Deposits

ppb = parts-per-billion; **ppm** = parts-per-million; **ppt** = parts-per-trillion; **pCi/L** = picoCuries per liter; **ntu** = nephelometric turbidity units; **ND** = not detected; **n/a** = not applicable; **n/r** = not regulated; **µmho/cm** = micromho per centimeter; **<** = average is less than the detection limit for reporting purposes; **MCL** = Maximum Contaminant Level;

(MCLG) = federal MCL Goal; **PHG** = California Public Health Goal; **RL** = Response Level. ***Contaminant is regulated by a secondary standard to maintain aesthetic quality.**

SUBURBAN WATER SYSTEMS LA MIRADA DISTRIBUTION SYSTEM WATER QUALITY TESTED IN 2021

Chemical (Units)	Met Standard?	MCL (MRDL/MRDLG)	Average	Range	Typical Source of Contaminant
Disinfection Byproducts					
Total Trihalomethanes (ppb)	Yes	80	51	5 - 140	Byproducts of Chlorine Disinfection
Haloacetic Acids (ppb)	Yes	60	10	ND - 25	Byproducts of Chlorine Disinfection
Chlorine Residual (ppm)	Yes	(4 / 4)	1	0.2 - 1.8	Disinfectant Added for Treatment
Aesthetic Quality					
Color (Color Units)	Yes	15*	<3	ND - 10	Erosion of Natural Deposits
Turbidity (ntu)	Yes	5*	0.2	ND - 5.9	Erosion of Natural Deposits
Odor (threshold odor number)	Yes	3*	1	1	Erosion of Natural Deposits
Eight locations in the distribution system are tested quarterly for total trihalomethanes and haloacetic acids; six locations are tested weekly for color, odor and turbidity. MRDL = Maximum Residual Disinfectant Level; MRDLG = Maximum Residual Disinfectant Level Goal; ntu = nephelometric turbidity units; ND = not detected; < = average is less than the detection limit for reporting purposes;					
*Contaminant is regulated by a secondary standard to maintain aesthetic qualities.					

Bacterial Quality	Met Standard?	MCL	MCLG	Percent Positive	Typical Source Of Contaminant
Total Coliform Bacteria	Yes	No more than 5% in a month	0		Bacteria that occur naturally in soils and water
Lead and Copper					
	Met Standard?	Action Level	PHG	90th Percentile	Typical Source Of Contaminant
Copper (ppm)	Yes	1.3	0.3	0.23	Corrosion of Household Plumbing
Lead (ppb)	Yes	15	0.2	<5	Corrosion of Household Plumbing

The most recent lead and copper at-the-tap samples were collected from residences in 2019. None of the 32 samples for lead and copper exceeded the respective Action Level (AL). A regulatory Action Level is the concentration of a contaminant which if exceeded triggers treatment or other requirements that a water system must follow.

Water Quality Goals

The water Suburban delivers to your home meets standards required by USEPA, SWB and California Public Utilities Commission (PUC). Often, Suburban goes beyond what is required to monitor for constituents that have known health risks. The company uses only independent, state-certified water quality laboratories for testing. The charts in this report include two types of water quality goals:

- Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.
- Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Water Quality Standards

The quality of drinking water in the United States is regulated by the USEPA. Two state agencies, the SWB and the PUC, supplement and enforce federal USEPA standards. Standards established by these agencies are used to set limits for substances that may affect health or aesthetic qualities of water. The water quality charts in this report cover the following standards:

- Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste and appearance of drinking water.
- Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Primary Drinking Water Standard (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, as well as water treatment requirements.
- Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.



Source Water and Water Quality Assessments


Suburban provides drinking water for its La Mirada service area (City of La Mirada and portions of La Habra, Fullerton and Buena Park) from its wells in the Main San Gabriel Groundwater Basin and the Central Groundwater Basin.



Suburban has completed source water assessments in accordance with the federal Safe Drinking Water Act. The purpose of the source water assessment is to promote source water protection by identifying types of activities in the proximity of sources which could pose a threat to the water quality.

Suburban's source water assessment was completed in 2002 and concluded that groundwater sources are most vulnerable to the following activities or facilities associated with contaminants detected in the water supply: leaking underground storage tanks, known contaminant plumes from industrial waste discharges, and gas stations. In addition, the sources are considered most vulnerable to the following activities and facilities not associated with contaminants detected in the water supply: pesticide/ fertilizer/petroleum storage and transfer areas, metal and machine shops, and agricultural drainage.

You may request a summary of the assessments by contacting Omar Tinoco at otinoco@swwc.com or you may request a complete copy from the SWB at (818)551-2049.



Testing for Lead in School Drinking Water Sources

All twelve public schools in Suburban's La Mirada system service area have been tested for lead in representative drinking fountains and food preparation water outlets. Suburban water quality technicians collected water samples at the schools and submitted the samples to a California-certified laboratory for lead analysis. Please consult your local schools for information regarding lead testing of drinking water sources.

The Quality of Your Water Is Our Primary Concern



This report contains important information
about your drinking water.
Translate it, or speak with someone who understands it.

يحتوي هذا التقرير على معلومات هامة عن نوعية ماء الشرب في منطقتك. يرجى ترجمته، أو ابحث التقرير مع صديق لك يفهم هذه المعلومات جيدا.

这份报告中有些重要的信息，讲到关于您所在社区的水的品质。请您找人翻译一下，或者请能看得懂这份报告的朋友给您解释一下。

इस रिपोर्ट में "पाने के पानी" के विषय पर बहुत जरूरी जानकारी दी गई है। कृपया इसका अनुवाद करें, या किसी जानकार से इस बारे में पूछें।

Arabic

Chinese

Hindi

この資料には、あなたの飲料水についての大切な情報が書かれています。内容をよく理解するために、日本語に翻訳して読むか説明を受けてください。

이 보고서는 귀하의 거주하는 지역의 수질에 관한 중요한 정보가 들어 있습니다. 이것을 번역하거나 충분히 이해하지는 친구와 상의하십시오.

Este reporte contiene información importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Japanese

Korean

Spanish

Ang ulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa iyong pag-inom ng tubig. Isalin ito, o makipag-usap sa isang tao na nauunawaan ito.

Bản báo cáo có ghi những chi tiết quan trọng về phẩm chất nước trong cộng đồng quý vị. Hãy nhờ người thông dịch, hoặc hỏi một người bạn biết rõ về vấn đề này.

Tagalog

Vietnamese



Public Participation Opportunities

We value your input, concerns and suggestions. Please contact Lauren James, Communications Manager, at (626) 543-2531 or email her at LJames@swwc.com to inquire about possible future public participation opportunities. Also, please feel free to contact Omar Tinoco, Environmental Compliance Specialist (626) 201-9732, if you have any questions about water quality. In addition, a number of local water boards hold monthly meetings that are open to the public, including:

Central Basin Municipal Water District
Fourth Monday of the month, (323) 201-5500

Water Replenishment District of Southern California
Third Thursday of the month, (562) 921-5521

San Gabriel Basin Water Quality Authority
Third Wednesday of the month, (626) 338-5555



Suburban Water Systems

A SouthWest Water Company

District Office: Whittier/La Mirada

15088 Rosecrans Avenue
La Mirada, California 90638

Customer Service: (562) 944-8219
SuburbanCustomerCare@swwc.com
www.swwc.com/suburban